From: Michael Lavender
Sent: 10 May 2019 15:32
To: Eve Hearsey
Subject: Fwd: AWDM/0188/19: Discharge of conditions

Hi Eve,

I never received a response to the e-mail below.

Michael

---------- Forwarded message ---------
From: **Michael Lavender** <michael.lavender@adur-worthing.gov.uk>
Date: Tue, 16 Apr 2019 at 09:34
Subject: AWDM/0188/19: Discharge of conditions
To: Eve Hearsey <eve.hearsey@adur-worthing.gov.uk>

Hi Eve,

apologies for the delay in responding to this.

The report advises that windows will need to be kept closed to achieve acceptable internal noise levels. Although not specified in the planning condition, we would usually ask for a MVHR system in such cases as opposed to trickle ventilation.

MVHR would be the preferred ventilation solution if possible but overall I am satisfied the required noise levels will be achieved.

Regards

--

Michael Lavender
Senior Environmental Health Officer, Adur & Worthing Councils
Phone: 01273 263343
Email: michael.lavender@adur-worthing.gov.uk
Website: Environmental Health
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



--

Michael Lavender
Senior Environmental Health Officer, Adur & Worthing Councils
Phone: 01273 263343
Email: michael.lavender@adur-worthing.gov.uk
Website: Environmental Health

Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

