from Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Your ref
AWDM/0599/23

Our ref
DSA000023193

Date
18/05/2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Erection of attached dwelling.
Site: AWDM/0599/23: - 1 Abbotts View, Sompting, West Sussex, BN15 0NG.

Thank you for your letter dated 27/04/2023.

Please see the attached extract from Southern Water records showing the approximate position of water distribution mains in the immediate vicinity of the development site. The exact position of the public assets must be determined on site by the applicant in consultation with Southern Water, before the layout of the proposed development is finalised.

- The 4 inches water distribution mains require a clearance of 6 meters on either side of the water distribution mains to protect it from construction works and to allow for future access for maintenance.

- No excavation, mounding or tree planting should be carried out within 6 meters of the external edge of the public water distribution mains without consent from Southern Water.

- No new soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 meters of a public water distribution mains.

- All existing infrastructure, including protective coatings and cathodic protection, should be protected during the course of construction works.

Please refer to: southernwater.co.uk/media/3011/stand-off-distances.pdf

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670