From: **FRS Water and Access** <FRSWaterandAccess@westsussex.gov.uk>
Date: Mon, 25 Nov 2024 at 11:41
Subject: RE: Worthing Business Park conditions AWDM/1244/24
To: Louise Prew <louise.prew@adur-worthing.gov.uk>

Hi Louise,

Having viewed the plan submitted, providing the fire hydrant indicated on the plan is in place, ready for use and West Sussex Fire & Rescue Service are informed it is ready for use prior to any occupation of any of the units the consultation raised will be met. Unfortunately, on to many occasions we are not informed the fire hydrant is ready for use prior to occupation, which then puts lives and properties at a greater risk in the event of a fire incident.

Regards

Ian