Gmail **Planning - <planning@adur-worthing.gov.uk>**

Fwd: FW: Shoreham Airport - Planning response 63697

1 message

Planning - <planning@adur-worthing.gov.uk> 1 February 2023 at 15:13
To: Planning - <planning@adur-worthing.gov.uk>

———- Forwarded message ———-
From: **Derek Magee** [redacted]
Date: Wed, 1 Feb 2023 at 13:15
Subject: Re: FW: Shoreham Airport - Planning response 63697
To: James Appleton [redacted]

Hi James,
Please see my comments below in blue.
The drainage information provide is adequate for the discharging of any surface water drainage conditions

Regards
Derek

On Thu, 26 Jan 2023 at 17:16, James Appleton [redacted] wrote:

> Derek please see response to comments raised about Airport discharge of conditions - grateful for your comments.
>
> James
>
> **James Appleton**
> Head of Planning and Development, Planning & Development
> [redacted]
> Adur & Worthing Councils
> Portland House
> Richmond Road
> Worthing
> West Sussex
> www.adur-worthing.gov.uk
>
> disability confident EMPLOYER
>
> ———- Forwarded message ———-
> From: **James Hicks** [redacted]
> Date: Thu, 26 Jan 2023 at 17:14
> Subject: FW: Shoreham Airport - Planning response 63697
> To: [redacted]
> Cc: Eleanor Overton [redacted]
>
> James
>
> Set our below and attached are the project engineers' responses to Derek comments on the drainage scheme.

We look forward to hearing that these matters are now addressed.

Regards

James Hicks
Senior Director

E [redacted]
M
4 The Courtyard | Lockington | Derby | DE74 2SL

Expertly Done. **LinkedIn | Twitter | Instagram | Our Charity | Our Website**

DESIGN | ECONOMICS | ENVIRONMENT | HERITAGE | LAND & PROPERTY | PLANNING | TRANSPORT & INFRASTRUCTURE
Offices throughout the UK and Ireland. We are ISO certified 9001, 14001, 45001. Pegasus Group is the trading name of Pegasus Planning Group Ltd [07277000] registered in England and Wales. Registered Office: Pegasus House, Querns Business Centre, Whitworth Road, Cirencester, Gloucestershire, GL7 1RT. This email and any associated files, is intended for the exclusive use of the addressee only. If you are not the intended recipient you should not use the contents nor disclose them to any other person. If you have received this message in error please notify us immediately. We have updated our Privacy Statement in line with GDPR; please click here to view it.

From: Myles Sturgess [redacted]
Sent: 16 January 2023 15:42
To: James Hicks [redacted]
Cc: Eleanor Overton [redacted] Gareth Evans [redacted] Joshua Butle[redacted]; Helen Sims [redacted] David McGougan [redacted] Barry Smith [redacted]; James Martin [redacted]
Subject: RE: Shoreham Airport - Planning response 63697

Hi James,

Below are my comments in RED

1. I would like to have catchment areas marked on a plan and the drainage calculations to justify the attenuation areas.

Micro drainage Area Plan CAD Export attached. Calculations attached. 1 in 1 year, 1 in 30 year with 40%CC, 1 in 100 year with 40%CC.
The calculations are satisfactory

2. Land drainage Consent will be required for the new headwall (NMF-CEP-06-DR-C-C-403-22236-6-403 C6)

This headwall was installed by CEP during the pumping station works which is understood to have had LDC at the time of works. This is not subject to our current RMA/discharge application.

Noted OK

3.Perforated pipework should be wrapped in a porous geotextile to prevent loss of fines.

Agreed, details as per attached Details drawing 62886 – 112 P2

OK

4. Please provide details of outfalls into swales

Althon Headwall details and installation details attached.

Drainage downpipes connect to the Swales using either the right-handed or left-handed AH4C Headwalls (to suit site requirements to direct water downstream at an angle)

Headwalls to the pipes connecting the swales are to be the H6C Headwall. All headwalls will require grating and kee klamp fall restraint railings.

Detail sheets attached listed below:

AH4c_Dataset_and_Installation_guide.pdf

H6c_Datasheet_and_Installation_Guide.pdf

H6CA Headwall + Sloped Grating + 3 Sided Kee Klamp.pdf

Thankyou

5. Tree planting adjacent to permeable areas should have root barriers provided.

As shown on the attached amended landscaping drawings.

Thankyou

Kind regards,

Myles Sturgess

Senior Civil Engineer

[redacted]



Engineering Excellence | Creating Advantage

[redacted]

Civil & Structural I Environmental I Highways I Surveying

PRP Northampton
Catherine House

Harborough Road
Brixworth
Northampton
NN6 9BX
Tel: [redacted]
Web : http://www.prp.uk.com/

Leicester I Northampton I London

Any opinions expressed in this email may not necessarily be those of PRP. The entire content of this email is confidential and solely for the use of the recipient (person or entity) to whom it is addressed and any opinions expressed in this email may not necessarily be those of PRP. The entire content of this email is confidential and solely for the use of the recipient (person or entity) to whom it is addressed and may contain material which is privileged or exempt from disclosure under applicable law. If you are not the intended recipient or the person responsible for delivering it to the intended recipient please delete it from your system and notify the sender by email (to itmanager@prp.uk.com) immediately. In this circumstance please accept our apologies, but you should note that any disclosure, dissemination, reproduction, distribution, use, or retention of this communication is strictly prohibited.

From: [redacted] **On Behalf Of** James Appleton
Sent: 12 January 2023 14:10
To: James Hicks [redacted]
Subject: Fwd: Shoreham Airport

James,

As discussed please find queries from our Drainage Engineer perhaps your Consultant could contact him direct to resolve.

James

James Appleton

Head of Planning and Development, Planning & Development

[redacted]

Adur & Worthing Councils

Portland House
Richmond Road
Worthing
West Sussex

www.adur-worthing.gov.uk

Image removed by sender. Image removed by sender. Image removed by sender.

[redacted]

Image removed by sender.

------ Forwarded message ------
From: **Derek Magee** [redacted]
Date: Thu, 12 Jan 2023 at 11:35
Subject: Re: Shoreham Airport
To: James Appleton [redacted]

Hi James,

Following our discussion on this application I have the following comments on the Surface Water Drainage proposals.

1. I would like to have catchment areas marked on a plan and the drainage calculations to justify the attenuation areas.

2. Land drainage Consent will be required for the new headwall (NMF-CEP-06-DR-C-C-403-22236-6-403 C6)

3.Perforated pipework should be wrapped in a porous geotextile to prevent loss of fines.

4. Please provide details of outfalls into swales

5. Tree planting adjacent to permeable areas should have root barriers provided.

Regards

Derek

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

–

Derek Magee
Engineer (Major Projects) Available Tuesdays Wednesdays & Thursdays, Facilities & Technical Services
[redacted]
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk


disability
confident
EMPLOYER