From: Planning - <planning@adur-worthing.gov.uk> on behalf of Planning -
Sent: 17 January 2023 16:20
To: Planning -
Subject: Fwd: Shoreham Airport

---------- Forwarded message ---------
From: **Derek Magee** <derek.magee@adur-worthing.gov.uk>
Date: Thu, 12 Jan 2023 at 11:35
Subject: Re: Shoreham Airport
To: James Appleton <james.appleton@adur-worthing.gov.uk>

Hi James,
Following our discussion on this application I have the following comments on the Surface Water Drainage proposals.
1. I would like to have catchment areas marked on a plan and the drainage calculations to justify the attenuation areas.
2. Land drainage Consent will be required for the new headwall (NMF-CEP-06-DR-C-C-403-22236-6-403 C6)
3.Perforated pipework should be wrapped in a porous geotextile to prevent loss of fines.
4. Please provide details of outfalls into swales
5. Tree planting adjacent to permeable areas should have root barriers provided.

Regards
Derek

Derek Magee
Engineer (Major Projects) Available Tuesdays Wednesdays & Thursdays, Facilities & Technical Services
1903221373
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk



