14/09/2018
WSCC Ecological Response to…

APPLICATION No.: AWDM/1706/16

PROPOSAL: Discharge of Condition 13

SITE: **The Bell 164 South Street Lancing West Sussex**

Subject to a minor modification there would be no objection to the appropriate discharge of condition 13.

Dwg No. L(04)1000 rev K etc. details a proposed sparrow terrace at 5m and swift box at 2m. Neither box will be used by the target species at these heights. The correct heights would see situation reversed.

I recommend that the Swift box is placed at +5m and the sparrow terrace at +2m.

Don Baker MCIEEM | Team Manager, Environment & Heritage, Planning Services, West Sussex County Council
Location: 1st Floor Northleigh, Tower Street, PO19 1RH
Internal: 26439 | External: +44 (0) 3302 226439 | E-mail: don.baker@westsussex.gov.uk

Think sustainably. Do you have to print? Can you double side? Do you need colour?