

From: **MBX-Planningconsents** <Planningconsents@ukpowernetworks.co.uk>
Date: Thu, 25 Jun 2026 at 12:15
Subject: RE: Planning Application Consultation for Montgomery Motors 37 Albion Street Southwick West Sussex AWDM/0723/26 COMMENTS
To: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>

Dear Sirs

Please find below our comments regarding the above matter, we have been unable to post them to your website as for some reason it is not allowing us to do so

Please note there are HV/LV underground cables running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 (Avoiding Danger from Underground services). This document is available from local HSE office.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website [Moving electricity supplies or equipment | UK Power Networks](#)

Kind Regards

Rikk Sowerby
Technical Support
Property & Consents

PlanningConsents@ukpowernetworks.co.uk
ukpowernetworks.co.uk
Barton Road, Bury St Edmunds IP32 7BG

Please be aware that my working hours are
Monday-Friday 7.30am – 1.30pm