from Southern Water

Planning Services
Adur & Worthing Councils
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/2034/22

Our ref
DSA000031615

Date
29 February 2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Installation of 1no. modular building on western side of rear car park to provide treatment rooms, including removal of raised planted area and garage in rear car park and reconfiguration of parking area.
Site: AWDM/2034/22: - Ball Tree Surgery, Western Road North, Sompting, West Sussex, BN15 9UX.

Thank you for your letter dated 13 February 2024.

It appears that the applicant is proposing to abandon/divert a public foul sewer. Any public sewer diversion proposals shall be approved by Southern Water under Section 185 of the Water Industry Act. An application should be made using Southern Water's Get Connected Service at developerservices.southernwater.co.uk

All other comments in our response dated 3 January 2024 remain unchanged and valid.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670