

Building Regulations England Part L (BREL) Compliance Report

Approved Document L1 2021 Edition, England assessed by Array SAP 10 program, Array

Date: Fri 15 May 2026 14:34:51

Project Information			
Assessed By	Joshua Cunningham	Building Type	Flat, Semi-detached
OCDEA Registration	EES/024531	Assessment Date	2026-05-15

Dwelling Details			
Assessment Type	As designed	Total Floor Area	77 m ²
Site Reference	Flat 29	Plot Reference	Design V1
Address	37 Flat 29 Albion Street, Southwick, BN42 4DN		

Client Details	
Name	PR HOMES DIRECT LIMITED
Company	PR HOMES DIRECT LIMITED
Address	168 Church Road, Hove, East Sussex, BN3 2DL

This report covers items included within the SAP calculations. It is not a complete report of regulations compliance.

1a Target emission rate and dwelling emission rate			
Fuel for main heating system	Electricity		
Target carbon dioxide emission rate	12.52 kgCO ₂ /m ²		
Dwelling carbon dioxide emission rate	3.81 kgCO ₂ /m ²		OK
1b Target primary energy rate and dwelling primary energy			
Target primary energy	66.92 kWh _{PE} /m ²		
Dwelling primary energy	40.29 kWh _{PE} /m ²		OK
1c Target fabric energy efficiency and dwelling fabric energy efficiency			
Target fabric energy efficiency	32.5 kWh/m ²		
Dwelling fabric energy efficiency	31.3 kWh/m ²		OK

2a Fabric U-values				
Element	Maximum permitted average U-Value [W/m ² K]	Dwelling average U-Value [W/m ² K]	Element with highest individual U-Value	
External walls	0.26	0.19	Walls (1) (0.19)	OK
Party walls	0.2	0	Party Wall (1) (0)	N/A
Curtain walls	1.6	0	N/A	N/A
Floors	0.18	N/A	N/A	N/A
Roofs	0.16	0.14	Roof (1) (0.14)	OK
Windows, doors, and roof windows	1.6	1.2	RW (1.2)	OK
Rooflights	2.2	N/A	N/A	N/A

2b Envelope elements (better than typically expected values are flagged with a subsequent (!))			
Name	Net area [m ²]	U-Value [W/m ² K]	
Exposed wall: Walls (1)	44.88	0.19	
Party wall: Party Wall (1)	40.31	0 (!)	
Exposed roof: Roof (1)	45.9	0.14	

2c Openings (better than typically expected values are flagged with a subsequent (!))				
Name	Area [m ²]	Orientation	Frame factor	U-Value [W/m ² K]
RW, Opening Type 1 - Window	1.22	South West	0.7	1.2
LSW, Opening Type 1 - Window	2.44	South East	0.7	1.2
LSGD, Opening Type 1 - Window	7.09	South East	0.7	1.2
RGD, Opening Type 1 - Window	7.09	South East	0.7	1.2
RSGD, Opening Type 1 - Window	7.09	North West	0.7	1.2

2d Thermal bridging (better than typically expected values are flagged with a subsequent (!))				
Building part 1: Thermal bridging calculated from linear thermal transmittances for each junction				
Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E2: Other lintels (including other steel lintels)	Not government-approved scheme	0.023 (!)	RCDs
External wall	E3: Sill	Not government-approved scheme	0.024 (!)	RCDs

Main element	Junction detail	Source	Psi value [W/mK]	Drawing / reference
External wall	E4: Jamb	Not government-approved scheme	0.019 (!)	RCDs
External wall	E16: Corner (normal)	Not government-approved scheme	0.037 (!)	RCDs
External wall	E7: Party floor between dwellings (in blocks of flats)	Not government-approved scheme	0.036 (!)	RCDs
Party wall	P3: Intermediate floor between dwellings (in blocks of flats)	Not government-approved scheme	0.036 (!)	RCDs
External wall	E25: Staggered party wall between dwellings	Not government-approved scheme	0.03 (!)	RCDs
External wall	E14: Flat roof	Calculated by person with suitable expertise	0.04	Assessed at Bregs Stage

3 Air permeability (better than typically expected values are flagged with a subsequent (!))

Maximum permitted air permeability at 50Pa	8 m ³ /hm ²	
Dwelling air permeability at 50Pa	3 m ³ /hm ² , Design value (!)	OK
Air permeability test certificate reference		

4 Space heating

Main heating system 1: Heat pump with radiators or underfloor heating - Electricity

Efficiency	259.4%
Emitter type	Radiators
Flow temperature	45°C
System type	Heat Pump
Manufacturer	Mitsubishi Electric Europe B.V.
Model	Ecodan 5.0 kW
Commissioning	

Secondary heating system: N/A

Fuel	N/A
Efficiency	N/A
Commissioning	

5 Hot water

Cylinder/store - type: Cylinder

Capacity	150 litres
Declared heat loss	1.6 kWh/day
Primary pipework insulated	Yes
Manufacturer	
Model	
Commissioning	

Waste water heat recovery system 1 - type: N/A

Efficiency	
Manufacturer	
Model	

6 Controls

Main heating 1 - type: Time and temperature zone control by arrangement of plumbing and electrical services

Function	
Ecodesign class	
Manufacturer	
Model	

Water heating - type: Cylinder thermostat and HW separately timed

Manufacturer	
Model	

7 Lighting

Minimum permitted light source efficacy	75 lm/W	
Lowest light source efficacy	95 lm/W	OK
External lights control	N/A	

8 Mechanical ventilation		
System type: Balanced whole-house mechanical ventilation with heat recovery		
Maximum permitted specific fan power	1.5 W/(l/s)	
Specific fan power	0.9 W/(l/s)	OK
Minimum permitted heat recovery efficiency	73%	
Heat recovery efficiency	88%	OK
Manufacturer/Model	Unknown - Planning Stage	
Commissioning		
9 Local generation		
Technology type: Photovoltaic system (1)		
Peak power	0.725 kWp	
Orientation	Horizontal	
Pitch	Horizontal	
Overshading	None or very little	
Manufacturer		
MCS certificate		
10 Heat networks		
N/A		
11 Supporting documentary evidence		
N/A		
12 Declarations		
a. Assessor Declaration		
This declaration by the assessor is confirmation that the contents of this BREL Compliance Report are a true and accurate reflection based upon the design information submitted for this dwelling for the purpose of carrying out the "As designed" assessment, and that the supporting documentary evidence (SAP Conventions, Appendix 1 (documentary evidence) schedules the minimum documentary evidence required) has been reviewed in the course of preparing this BREL Compliance Report.		
Signed:	Assessor ID:	
Name:		
	Date:	
b. Client Declaration		
N/A		

Summary for Input Data



Plot Reference	Flat 29	Issued on Date	15/05/2026
Assessment Reference	Design V1	Plot Type Ref	1 Bed
Plot Address	Flat 29, 37, Albion Street, Southwick, Hove, BN42 4DN	SAP Version	10.2

SAP Rating	84 B	DER	3.81	TER	12.52
Environmental	97 A	% DER < TER			69.57
CO ₂ Emissions (t/year)	0.27	DFEE	31.34	TFEE	32.48
Compliance Check	See BREL	% DFEE < TFEE			3.51
% DPER < TPER	39.79	DPER	40.29	TPER	66.92

Assessor Details	Mr. Joshua Cunningham	Assessor ID	Y502-0001
Client	QU-0145, PR HOMES DIRECT LIMITED		

SUMMARY FOR INPUT DATA FOR: New Build (As Designed)

Orientation	Northeast	
Property Tenture	ND	
Transaction Type	6	
Terrain Type	Urban	
1.0 Property Type	Flat, Semi-Detached	
Position of Flat	Mid-floor flat	
Which Floor	4	
2.0 Number of Storeys	1	
3.0 Date Built	2026	
4.0 Sheltered Sides	2	
5.0 Sunlight/Shade	Average or unknown	
6.0 Thermal Mass Parameter	Enter TMP value	
Thermal Mass	350.00	kJ/m²K
7.0 Electricity Tariff	Standard	
Smart electricity meter fitted	Yes	
Smart gas meter fitted	No	

7.0 Measurements		Heat Loss Perimeter	Internal Floor Area	Average Storey Height
	Ground floor:	23.27 m	77.22 m ²	3.00 m

8.0 Living Area	27.16	m ²
-----------------	-------	----------------

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Gross Area(m ²)	Nett Area (m ²)	Shelter Res	Shelter	Openings	Area Calculation Type
External Wall 1 - Masonry	Cavity Wall	Cavity wall; plasterboard on dabs or battens, lightweight aggregate block, filled cavity, any outside structure	0.19		69.81	44.88	0.00	None	24.93	Enter Gross Area

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Area (m ²)	Shelter Res	Shelter
Party Wall 1	Filled Cavity with Edge Sealing	Single plasterboard on both sides, dense cellular blocks, cavity	0.00		40.31	0.00	None

Description	Type	Construction	U-Value (W/m ² K)	Kappa (kJ/m ² K)	Gross Area(m ²)	Nett Area (m ²)	Shelter Code	Shelter Factor	Calculation Type	Openings
External Roof 1 - Warm Deck	External Flat Roof	Plasterboard, insulated flat roof	0.14	9.00	45.90	45.90	None	0.00	Enter Gross Area	0.00

Description	Construction	Kappa (kJ/m ² K)	Area (m ²)
Party Ceiling 1	Precast concrete planks floor, screed, carpeted	30.00	31.32

Description	Storey Index	Construction	Kappa (kJ/m ² K)	Area (m ²)
-------------	--------------	--------------	-----------------------------	------------------------

Summary for Input Data

Party Floor 1 Lowest occupied Precast concrete planks floor, screed, carpeted 40.00 77.22

12.0 Opening Types

Description	Data Source	Type	Glazing	Glazing Gap	Filling Type	G-value	Frame Type	Frame Factor	U Value (W/m²K)
Opening Type 1 - Window	Manufacturer	Window	Double Low-E Soft 0.1			0.63		0.70	1.20

13.0 Openings

Name	Opening Type	Location	Orientation	Area (m²)	Pitch
RW	Opening Type 1 - Window	External Wall 1 - Masonry	South West	1.22	
LSW	Opening Type 1 - Window	External Wall 1 - Masonry	South East	2.44	
LSGD	Opening Type 1 - Window	External Wall 1 - Masonry	South East	7.09	
RGD	Opening Type 1 - Window	External Wall 1 - Masonry	South East	7.09	
RS GD	Opening Type 1 - Window	External Wall 1 - Masonry	North West	7.09	

14.0 Conservatory

None

15.0 Draught Proofing

100 %

16.0 Draught Lobby

No

17.0 Thermal Bridging

Calculate Bridges

17.1 List of Bridges

Bridge Type	Source Type	Length	Psi	Adjusted Reference:	Imported
E2 Other lintels (including other steel lintels)	Non Gov Approved Schemes	12.15	0.02	0.02 RCDs	No
E3 Sill	Non Gov Approved Schemes	2.70	0.02	0.02 RCDs	No
E4 Jamb	Non Gov Approved Schemes	21.60	0.02	0.02 RCDs	No
E16 Corner (normal)	Non Gov Approved Schemes	6.00	0.04	0.04 RCDs	No
E7 Party floor between dwellings (in blocks of flats)	Non Gov Approved Schemes	23.27	0.04	0.04 RCDs	No
P3 Party wall - Intermediate floor between dwellings (in blocks of flats)	Non Gov Approved Schemes	12.95	0.04	0.04 RCDs	No
E25 Staggered party wall between dwellings	Non Gov Approved Schemes	6.00	0.03	0.03 RCDs	No
E14 Flat roof	Independently assessed	19.68	0.04	0.04 Assessed at B'regs Stage	No

Y-value 0.03 W/m²K

19.0 Mechanical Ventilation

Mechanical Ventilation

Mechanical Ventilation System Present	Yes
Mechanical Ventilation data Type	Data Sheet
Type	Balanced mechanical ventilation with heat recovery
Manufacturer SFP	0.90
Duct Type	Rigid
MVHR Efficiency	88.00
Wet Rooms	2
Brand, Model	Unknown - Planning Stage
SFP from Installer Commissioning Certificate	No
MVHR System Location	Inside heated envelope (installed exclusively)
Duct Installation Specification	Level 1

20.0 Fans, Open Fireplaces, Flues

Number of open chimneys	0
Number of open flues	0
Number of chimneys/flues attached to closed fire	0
Number of flues attached to solid fuel boiler	0
Number of flues attached to other heater	0
Number of blocked chimneys	0
Number of intermittent extract fans	0
Number of passive vents	0
Number of flueless gas fires	0

21.0 Fixed Cooling System

No

22.0 Pressure Testing

Yes

Designed AP₅₀ 3.00 m³/(h.m²) @ 50 Pa

Summary for Input Data

Test Method

Blower Door

22.0 Lighting

No Fixed Lighting

No

Name
Lighting

Efficacy
95.00

Power
5.00

Capacity
475.00

Count
10

24.0 Main Heating 1

Percentage of Heat

100.00

%

Database Ref. No.

104569

Fuel Type

Electricity

In Winter

259.41

In Summer

176.78

Model Name

Ecodan 5.0 kW

Manufacturer

Mitsubishi Electric Europe B.V.

System Type

Heat Pump

Controls SAP Code

2207

Controls description

Time and temperature zone control by arrangement

Is MHS Pumped

Pump in heated space

Heating Pump Age

2013 or later

Heat Emitter

Radiators

Flow Temperature

Enter value

Flow Temperature Value

45.00

25.0 Main Heating 2

None

26.0 Heat Networks

None

27.0 Secondary Heating

None

28.0 Water Heating

Water Heating

Main Heating 1

SAP Code

901

Flue Gas Heat Recovery System

No

Waste Water Heat Recovery Instantaneous System 1

No

Waste Water Heat Recovery Instantaneous System 2

No

Waste Water Heat Recovery Storage System

No

Solar Panel

No

Water use <= 125 litres/person/day

Yes

Cold Water Source

From mains

Bath Count

1

Immersion Only Heating Hot Water

No

28.1 Showers

Description

Shower Type

Flow Rate
[l/min]

Rated Power
[kW]

Connected

Connected To

Shower
2

Combi boiler or unvented hot water system
Combi boiler or unvented hot water system

9.00
9.00

No
No

28.3 Waste Water Heat Recovery System

29.0 Hot Water Cylinder

Cylinder Stat

Yes

Cylinder In Heated Space

Yes

Independent Time Control

Yes

Insulation Type

Measured Loss

Cylinder Volume

150.00

L

Loss

1.60

kWh/day

Summary for Input Data

Pipes insulation

Fully insulated primary pipework

31.0 Thermal Store

None

32.0 Photovoltaic Unit

Multiple Dwellings – Connected

Export Capable Meter?

No

Connected To Dwelling

Yes

Diverter

No

Battery Capacity [kWh]

0.00

PV Cells kWp

Orientation

Elevation

Overshading FGHRs

MCS Certificate

**Overshading
Factor**

**MCS
Certificate
Reference**

**Panel
Manufacturer**

0.72

Horizontal

Horizontal

None Or Little

No

1.00

34.0 Small-scale Hydro

None

Jan

Feb

Mar

Apr

May

Jun

Jul

Aug

Sep

Oct

Nov

Dec

Recommendations

Lower cost measures

None

Further measures to achieve even higher standards

None

Thermal Bridging

Plot Reference	Flat 29	Issued on Date	15/05/2026
Assessment Reference	Design V1	Plot Type Ref	Semi-Detached Flat
Plot Address	Flat 29, 37, Albion Street, Southwick, Hove, BN42 4DN	SAP Version	10.2

SAP Rating	84 B	DER	3.81	TER	12.52
Environmental	97 A	% DER < TER			69.57
CO ₂ Emissions (t/year)	0.27	DFEE	31.34	TFEE	32.48
Compliance Check	See BREL	% DFEE < TFEE			3.51
% DPER < TPER	39.79	DPER	40.29	TPER	66.92

Assessor Details	Mr. Joshua Cunningham	Assessor ID	Y502-0001
Client	QU-0145, PR HOMES DIRECT LIMITED		

	Junction details	Source Type	Psi (W/mK)	Length (m)	Result	Reference
External wall	E2 Other lintels (including other steel lintels)	Non Gov Approved Schemes	0.023	12.15	0.28	RCDs
External wall	E3 Sill	Non Gov Approved Schemes	0.024	2.70	0.06	RCDs
External wall	E4 Jamb	Non Gov Approved Schemes	0.019	21.60	0.41	RCDs
External wall	E16 Corner (normal)	Non Gov Approved Schemes	0.037	6.00	0.22	RCDs
External wall	E7 Party floor between dwellings (in blocks of flats)	Non Gov Approved Schemes	0.036	23.27	0.84	RCDs
Party wall	P3 Party wall - Intermediate floor between dwellings (in blocks of flats)	Non Gov Approved Schemes	0.036	12.95	0.47	RCDs
External wall	E25 Staggered party wall between dwellings	Non Gov Approved Schemes	0.030	6.00	0.18	RCDs
External wall	E14 Flat roof	Independently assessed	0.040	19.68	0.79	Assessed at B'regs Stage

Total: 104.35 W/mK:
Y-Value: 0.03 W/m²K: