From:	planning@adur-worthing.gov.uk
Sent:	23 August 2019 15:40
To:	planning@adur-worthing.gov.uk
Subject:	Consultee Comments for Planning Application AWDM/1159/19

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 3:47 PM on 23 Aug 2019 from Mr Michael Lavender (michael.lavender@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1159/19
Address:	Land North Of 1 To 28 The Haven Brighton Road Lancing West Sussex
Proposal:	Construction of 10no. flats (8 x 2 bed and 2 x 3 bed) within 2 storey building, with 9no. parking spaces, 10no. cycle spaces, amenity space and landscaping.
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	From: Michael Lavender Date: Fri, 23 Aug 2019 at 15:35 Subject: AWDM/1159/19: Land North Of 1 To 28 The Haven, Brighton Road, To: Peter Barnett Hi Peter, I have no objections to the above application subject to a condition stipulating the glazing specifications outlined in the applicants acoustic report and a MVHR ventilation system, which should include a summer bypass, for each dwelling. Regards -- Michael Lavender