From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 01 November 2024 16:27:43 UTC+00:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/1244/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 01/11/2024 4:27 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1244/24
Address:	Worthing Business Park Dominion Way Worthing West Sussex
Proposal:	Approval of Details Reserved by Conditions 9 (secure cycle parking), 10 (EVC spaces), 13 (fire hydrants), 15 (no external lighting or floodlighting), 22 (any changes to the Energy Use and Sustainability Statement) and 24 (Travel Plan) of Application AWDM/0510/22.
Case Officer:	Louise Prew

Click for further information

Comments Details

Comments:	With respect to Condition 10 (EV charge points), the proposed 7kw charging units appear to be acceptable. The Air Quality Impact Assessment submitted as part of the original application recommended 16 EV charge points be provided. The transport statement states 13 active chargers will be provided, with all other spaces having passive provision. Some clarity is therefore needed on what will actually be provided.

Kind regards