WORTHING BOROUGH COUNCIL

Mr Daniel Reynolds
Hemiko
Castletown Office
Rockcliffe
Carlisle
Cumbria
CA6 4BN
United Kingdom

TOWN AND COUNTRY PLANNING ACT 1990 (as amended)

APPLICATION NUMBER: AWDM/1196/26

Details of Development
APPROVAL OF DETAILS RESERVED BY CONDITION 09 (NOISE MITIGATION) OF APPROVED APPLICATION AWDM/1212/24.

Location of Development
ROOF MULTI STOREY CAR PARK HIGH STREET WORTHING WEST SUSSEX

The Authority has considered your application, and I can confirm the following condition(s) have been **APPROVED** subject to satisfactory implementation and in accordance with the approved plans.

G Peck

Gary Peck
Head of Planning & Development
17/11/2026

Adur & Worthing Councils, Development Management, Place Directorate,
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
Tel: 01903 221065 Email: planning@adur-worthing.gov.uk
Web: www.adur-worthing.gov.uk

SCHEDULE

Approved Date - 17/11/2026

9 Within 35 days from the date of this permission, the KP Acoustic Report, Reference 26677.PCR.01 dated 12/10/23 which was submitted with application AWDM/1439/23, shall be updated to take into account the revised position of the plant, the specific details of the chosen product, and any additional noise mitigation. Thereafter, this updated report shall be submitted to the local planning authority in writing for approval to demonstrate that the original noise objectives have been achieved. In the event that the original noise objectives have not been achieved, then notwithstanding the installation of the plant hereby approved, the air source heat pumps shall not be used until a further scheme of attenuation works capable of achieving the objectives as specified have been submitted and agreed in writing by the Local Planning Authority. Following installation, the Air Source Heat Pumps, acoustic barrier, and any further attenuation measures as may be agreed, shall be retained for the lifetime of the development and maintained in accordance with the manufacturer's recommendations.

Reason: *To safeguard the amenities of nearby residential occupiers and to comply with policies DM5 and DM22 of the Worthing Local Plan and the NPPF.*

Plans Referred to in Consideration of this application

The application has been assessed and the decision is made on the basis of the following plans and documents submitted:

Reference/Drawing Number	Version	Date Rec
NOISE ASSESSMENT REPORT	26677.PCR.01 Rev I	19.10.2026

Reason: *For the avoidance of doubt and in the interests of proper planning.*