Development Management - Delegated Officer Report

Application Number: AWDM/1593/23 Recommendation – APPROVE

Site: 59 Church Green, Shoreham-by-Sea, BN43 6JQ

Proposal: Application for a Lawful Development Certificate for proposed rear dormer.

Date of site visit: N/A: Assessment has also been assisted using the Applicants plan; Earthlight mapping; and Google 3D of the site

Neighbours checked: Y

Additional neighbour notifications: N

Site and Surroundings:

The application site is a two storey, middle of terrace dwelling, and has an existing rear, single storey extension. The dwelling is positioned on the south side of Church Green, which is a cul-de-sac. There is some open land to the rear site relating to a commercial use.

Properties in the area are predominantly two storey residential, and many have rear extensions, and some have rear dormers. There are also commercial properties within the close locality.

The site is not a Listed Building or within a Conservation Area.

Relevant Planning History: None

Proposal:

A Certificate of Lawfulness is sought for a:-

- A flat roof rear dormer;

Planning Assessment

Principle

Class B – additions etc. to the roof of a dwellinghouse

Permitted Development

B The enlargement of a dwellinghouse consisting of an addition or alteration to its roof

Development not permitted

B.1 Development is not permitted by Class B if:-

a) The dwellinghouse has been granted only by virtue of Class G, M, MA, N, P, PA or Q.

Analysis: The dwellinghouse has not been created through change of use by virtue of Part 3.

b) The height of the roof extension would exceed the highest part of the existing roof;

Analysis: The flat roof of the rear dormer is below the highest part (ridge) of the existing roof.

(c) the roof extension would extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;

Analysis: The rear dormer will not be onto the principal elevation etc.

(d) the cubic content of the resulting roofspace would exceed the cubic content of the original roof by more than:-
i) 40 cubic metres in the case of a terrace house, or
ii) 50 cubic metres in any other case.

Analysis: The submitted plan has been notated with the external measurements of the dormer as being 3.208m x 2.325m and measures to be approx. 3.2m deep. Which calculates the cubic capacity of the rear dormer, to be 12.20m^3

(e) it would consist of or include:-
i) the construction or provision of a verandah, balcony or raised platform, or
ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe;

Analysis: None of the above.

(f) the dwellinghouse is on article 2(3) land

Analysis: The dwelling house is not on article 2(3) land.

(g) the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses); or

Analysis: The dwellinghouse has not been created by virtue of Part 20.

(h) the existing dwellinghouse has been enlarged in reliance on the permission granted by Class AA (enlargement of a dwellinghouse by construction of additional storeys).

Analysis: The above does not apply.

B.2 Development is permitted subject to the following conditions:-

(a) the materials used in any exterior work must be of similar appearance to those used in the construction of the exterior of the existing house;

Analysis: The submitted plans are notated and say 'Tiles hung to match existing'.

(b) the enlargement must be constructed so that:-

i) other than in the case of a hip-to-gable enlargement which joins the original roof to the roof of a rear or side extension –

(aa) the eaves of the original roof are maintained or reinstated; and

(bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2m from the eaves, measured along the roof slope from the outside edge of the eaves, and

ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension no part of the enlargement extends beyond the outside face of any external wall of the original dwelling house.

Analysis: The proposal complies with the above.

c) any window inserted on a wall or roof slope forming a side elevation of the dwelling house must be:-

i) obscure glazed and
ii) non-opening unless the parts of the window which can be opened are more than 1.7m above the floor of the room in which the window is installed.

Analysis: There is no new window shown to be included within the sides of the dormer.

Recommendation

Issue a Certificate of Lawfulness as the proposal is permitted development by Class B within Schedule 2 Part 1 of Town and Country Planning (General Permitted Development) (England) Order 2015 as amended.

Reasons for Recommendation

The proposal constitutes 'development' as defined by Section 55 of the Town and Country Planning Act 1990, and is permitted by Class B of Schedule 2, Part 1 of the Town and Country Planning (General Permitted Development) (England) Order 2015, as amended.

Case Officer: Eve Hearsey Date: 18.01.2024

Authorised by: Peter Barnett Date: 18 January 2024