Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

ADUR & WORTHING
- 9 OCT 2015
PLANNING SERVICES

Your Ref
AWDM/1381/15
Our Ref
PLAN-011341
Date
07/10/2015

Dear Sir

Proposal: Extension of existing outpatients building to provide new departmental entrance, additional clinical floor space, enlarged roof top plant room and additional roof plant enclosure. Existing plant room to be overclad.
Site: Southlands Hospital, Upper Shoreham Road, Shoreham-By-Sea, West Sussex BN43 6TQ.
AWDM/1381/15

Thank you for your letter of 25/09/2015.

The attached plan shows that the existing development lies over a water distribution mains. If the works to be carried out will alter the existing foundation line or depth it will be necessary for the applicant to contact Southern Water. No excavation, mounding should be carried out close to public water main without consent from Southern Water.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

Southern Water requires a formal application for any new connection to the public foul and surface water sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:
"A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk

Yours sincerely

Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

Southern Water

O.S. REF: TQ2206SE	Scale: 1:1000	Printed By: banuh	Date: 7-10-2015
Screen Print		Southern Water MapGuide Browser	
WARNING: BAC pipes are constructed of Bonded Asbestos Cement		Requested By:	
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement			