From: Bruce Reynolds
Sent: 21 July 2009 09:37
To: Hannah Barker
Subject: ADC/0258/09 Single-storey east side elevation (to form annex for dependent relative) and raised timber decking at rear with balustrading and steps

Dear Hannah

I have now reviewed the above application and would note that there are no objections on environmental health grounds, although the degree of overlooking would appear to be considerable from the raised decking area. I would note that living accommodation is now located over a drainage manhole and that the cover needs to be double sealed and screwed down, but this should be covered under Building Regulations.

If you require any further information, please do not hesitate to contact me.

Yours sincerely

Bruce Reynolds
Senior Environmental Health Officer
Adur District Council

Tel: (01273) 263098: Fax: (01273) 263014 : e-mail : bruce.reynolds@adur.gov.uk
---
Domestic & Pollution Team
Housing, Health & Community Safety
Room 116, Civic Centre, Ham Road, Shoreham-by-Sea, West Sussex BN43 6PR

You can visit Adur DC's website at: http://www.adur.gov.uk

Please consider the environment, only print out this e-mail if absolutely necessary.