Consultee Comments for Planning Application AWDM/1656/20

1 message

planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk> 22 October 2020 at 11:10
To: planning@adur-worthing.gov.uk

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11:09 AM on 22 Oct 2020 from Miss Gabrielle Peak (gabrielle.peak@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/1656/20
Address:	Land North Of 56 Dolphin Road And East Of 50 Dolphin Road Shoreham-By-Sea West Sussex
Proposal:	Approval of Details Reserved by Condition 4 (Contamination) of application number AWDM/0760/20.
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	In regards to AWDM/1656/20 - The discharge is acceptable so long as raised planters are used with certified clean soil. Please ensure you send documentation to show that the soil in the planters is certified clean. Also, any excavated material should be removed from site immediately, if not possible is should be stored on an impermeable base and covered. WAC testing of all excavated soil should be undertaken and we would want to see the certificates as well as waste transfer notes for exported soil. Also, the advice in s. 7.6 concerning construction workers should be followed.