From: planning@adur-worthing.gov.uk
Sent: 11 April 2024 12:44:54 UTC+01:00
To: jo.morin@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/0317/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11/04/2024 12:44 PM from Mr Oliver Rochford (oliver.rochford@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0317/24
Address:	Former Horton Buildings Goring Street Worthing West Sussex
Proposal:	Approval of Details Reserved by Conditions 29 (New plant noise + TEST) and 30 (Implement in accordance with NIA + test) of Application AWDM/0833/21.
Case Officer:	Jo Morin

Click for further information

Comments Details

Comments:	A document titled Noise Technical Report (Ref:R8791-4 Rev 0, dated 28/02/2024) was submitted in support of the discharge of Condition 30 of planning application AWDM/0833/21. I am satisfied that the report demonstrates compliance with the levels specified in BS8233:2014 and recommend the discharge of condition 30.

Kind regards