From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 30 January 2025 00:01:23 UTC+00:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Comments for Planning Application AWDM/1549/24

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 30/01/2025 12:01 AM from Mr stewart hobbs.

Application Summary

Address:	37 Windsor Road Worthing West Sussex BN11 2LZ
Proposal:	Air source heat pump to rear
Case Officer:	Finlay Gardner

Click for further information

Customer Details

Name:	Mr stewart hobbs
Address:	14 Gannon Road, Worthing, West Sussex BN11 2DT

Comments Details

Commenter Type:	Neighbour
Stance:	Customer made comments neither objecting to or supporting the Planning Application
Reasons for comment:	- Privacy Light and Noise
Comments:	I would just like to take a moment to comment on the 'supported statement' that has recently been added regarding the concerns over noise. MCS 020 Planning standards for the air sorted heat pumps (which is the calculator that has been used) is a useful tool and 42Db(A) which is the max permitted output for domestic residential instillation is indeed the best case scenario for this pump when measured 2 meters and south of the boundary wall. However, if you recalculate at 4 metres North or West where there

is no wall to act as a sound barrier the calculated figure is 43Db(A)

I don't know how audible this will be to neighbours but any constant ambient sound is annoying and I know there are concerns.

Either way it helps to consider the full picture

Kind regards

Kind regards