Daniel Taylor
4 Weavers Court
Ropetackle
Shoreham By Sea
Sussex
BN43 5ES

[redacted]

EXE
DEPARTMENT
08 JUN 2010

7th June 2010

Your Ref: ADC/0170/10 – 4 Weavers Court, Ropetackle, Shoreham, BN43 5ES

Dear Mr. Hone,

Many thanks for your letter dated 28th May 2010, and for taking the time to speak with me this afternoon with regards to the above quoted planning application.

Following on from your letter and our subsequent telephone conversation please find enclosed a revised drawing reflecting two changes:

- Replacement of clear-glazed casement window with a awning (top-opening above line of sight) window of the same size, but with obscured glazing.
- Addition of stone sill placed beneath the window in order to made the window more sympathetic to the design of the rest of the Ropetackle development.

I have also enclosed a revised window specification reflecting the changes.

You will note that I have not included your recommendations to include an arched soldier course above the window as per your recommendation. This is because the top of the window will be against the existing vent/fascia as per all other windows on our property (please see photo example 1 below).

I have also omitted to include your recommendation of a brick quoin around the edge of the window. Again, having looked at the rest of the Ropetackle development this is not something that has been included on any other window located upon a rendered finish (please see photo examples 2, 3 and 4 below).



Photo 1 – Showing south elevation of 4 Weavers Court. Note no arched soldier course above first floor windows.



Photo 2 – Showing east elevation of 14-20 Weavers Court with rendered finish. Note no brick quoin.



Photo 3 – Showing north elevation of Marline Court with rendered finish. Note no brick quoin.



Photo 4 – Showing east elevation of houses in Ropetackle featuring rendered finish and no brick quoin.

I trust that these revisions will be enough to satisfy your requirements.

However should you have any further questions and / or comments then please do feel free to contact me.

Yours Sincerely



Daniel Taylor