

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 29 November 2024 08:55:07 UTC+00:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Planning consultation - AWDM/1492/24 Development Site 3 To 19 New Road Shoreham-by-sea West Sussex

FAO: Rebecca Perris

Dear Rebecca,

Having viewed the plans for the planning application no AWDM/1492/24 for the proposed 2no. detached dwellings and associated landscaping and parking; evidence is required to show that all points inside both domestic dwelling houses are within 45 metres of a fire appliance location in accordance with Approved Document B Volume 1 2019 Edition B5 section 13. This is to be measured along the hose lay route, not in a direct line or arc measurement, as this type of measurement is very rarely achievable due to obstructions. Any areas not within the 45-metre distance will need to be mitigated by the installation of domestic sprinkler or water mist system complying with BS9251 or BS8458 standard.

Regards

Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** 07921 291051

Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before

opening any attachment.
