From: **SouthernWater PlanningConsultations** <SouthernWater.PlanningConsultations@southernwater.co.uk>
Date: Mon, 14 Jul 2025 at 11:13
Subject: RE: FW: AWDM/0595/25 - 14 Halewick Close - DSA000043072
To: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>

Good morning,

Following the review of the submitted email below advising the proposed soakaway is the required 5m from the public sewer.

Therefore, Southern Water has no objections to the proposed works.

Yours
faithfully,

Kelly Donaldson

Future Growth Planning

Developer Services