Peter Barnett
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

8 July 2024

Dear Peter,

RE: **AWDM/0820/24 - Development Site At 26 And 27 East Street And 3 To 9 New Road Shoreham-by-sea West Sussex.**

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the approval of details reserved by Condition 6 (foul and surface water drainage details) of application AWDM/1419/23. The application is to Adur District Council.

Following a review of the submitted information, we have noted that insufficient information has been provided to satisfy the wording of Condition 6 and would therefore **recommend Condition 6 is not discharged**. No evidence of a ground investigation has been provided that demonstrates that infiltration is not a feasible option for surface water drainage. Therefore, the application has not followed the hierarchy of preference and is not in accordance with the Planning Policy Guidance (PPG).

Reason
To prevent flooding in accordance with National Planning Policy Framework paragraphs 165-175 by ensuring the satisfactory management of local flood risk, surface water flow paths, storage, and disposal of surface water from the site in a range of rainfall events and ensuring the SuDS proposed operates as designed for the lifetime of the development.

Yours sincerely,

Sustainable Water Management Officer

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511