From: Ian Stocks <ian.stocks@westsussex.gov.uk> on behalf of FRS Water and Access
Sent: 20 July 2020 09:36
To: planning@adur-worthing.gov.uk
Subject: Hydrant condition - AWDM/0957/20 28 Ring Road, Lancing, West Sussex, BN15 0QE
Attachments: Hydrant Condition _ AWDM.0957.20 28 Ring Road Lancing BN15 0QE.docx

Flag Status: Flagged

FAO: Peter Barnett

Dear Peter,

Please find attached a planning condition for application no. AWDM/0957/20 for the requirement of an additional fire hydrant. Currently the nearest Hydrant to these proposed properties is 210 metres away. The supply of water for firefighting for a domestic premises should be within 175 metres.

Regards

Ian Stocks
Water & Access manager

Water and Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
Phone: 0330 222 3117 | E-mail: frs.waterandaccess@westsussex.gov.uk

Living Our Values Every Day



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to

ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.