Matt Brockhurst

From:	Simon Barrett
Sent:	22 July 2024 11:57
To:	Will Court; Angell, Matt; Matt Brockhurst
Cc:	AASussexLtd
Subject:	Durrington Performing Arts Centre - Report
Attachments:	J3310 - Durrington Performing Arts Centre - Final Breakout Assessment - July 2024.pdf

Dear Will, Matt and Matt,

Please find attached my noise breakout assessment report for Durrington Performing Arts Centre.

In summary, there is zero change to the sound level at the boundary with the nearest residence when the PA is switched on even at the highest SPL that the staff dictated.
In fact, the measured sound level was lower. This shows it has no effect on the area and I recommend the planning condition is discharged.

Kind Regards,

Simon Barrett BSc(Hons) MSc MIOA

Acoustic Consultant | Robust Details Inspector | Air Tightness Manager | IT Admin

Acoustic South East

Email (Direct):

DDI:

Tel:

Address:

DISCLAIMER: The information in this email including any attached files is confidential and intended for the recipient(s) only. If you have received this email in error, please delete it. Acoustic South East cannot be held liable for any misuse of the email and/or its related content. While all emails sent are scanned for viruses before sending, it remains the responsibility of the recipient(s) to scan their incoming emails for viruses before downloading and/or opening the content.

Acoustic South East is a Trading Name of Acoustic Associates Sussex Ltd - Company Registration No.: 5646519