Rebekah Hincke
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

24 March 2026

Dear Rebekah,

RE: **AWDM/1132/25 - 6 Seamill Park Crescent Worthing West Sussex BN11 2PN.**

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the single storey rear extension with decking and balustrades, front porch, hip to barn end roof extensions with front and rear dormers. The application is to Worthing Borough Council.

Following a review of the submitted information, we have noted that the submitted Flood Risk Assessment is sufficient to demonstrate the application is in accordance with the NPPF and its accompanying PPG. Therefore, due to the site, size, location, and type of development **we would recommend the approval of the application** with the following informative attached:

Informative 1: The applicant must follow the drainage hierarchy of preference. Due to the size and location of the development, an infiltration test should be carried out in accordance with the Part H2, paragraph 1.34 to 1.37 of the Building Regulations (https://assets.publishing.service.gov.uk/media/5a80cf9ded915d74e33fc8ae/BR_PDF_AD_H_2015.pdf). This rate should then be put into the calculation in Part H3, paragraph 3.28. Following this the applicant can use the free tools at https://www.uksuds.com/ to size the soakaway for the 1 in 100 (1%) plus CC event.

If infiltration fails, the same links should be used to size attenuation storage to ensure surface water runoff does not increase from the existing discharge rate.

To obtain the relevant rainfall data the applicant can visit https://fehweb.ceh.ac.uk/ to download the point data for their site and input the csv file into the tools above.

Yours sincerely,

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511

Sustainable Water Management Officer