RE: AWDM/1831/20 - 23A Dolphin Road Shoreham-By-Sea

1 message

Liam Williams [redacted] 18 November 2020 at 11:53
To: Elaine Rousseau <elaine.rousseau@adur-worthing.gov.uk>

Hi Elaine,

Please find attached a block plan with arrow. I have taken some decibel readings with our meter which is a UNI-T UT352 (see picture attached), the meter is within calibration. The findings were as follows with no sound attenuating mediums between the fan and the meter. The fan was running at optimal speed for our operation-

1 meter- 73.5db

2 meters- 72db

3 meters- 70.5db

5 meters- 69.5db

10 meters- 56db

The nearest house is 30m + away. Normal conversation is in the region of 60db.

I am awaiting an elevation plan from build-a-plan, this should conclude what you need from us. I'm presuming the elevation plan will be just the front of the building as per below? There really isn't much to see as its just the 2 pipes arrowed below.