From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 02 April 2024 12:30:24 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0413/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 02/04/2024 12:30 PM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0413/24
Address:	5 Broadwater Street East Worthing West Sussex BN14 9AA
Proposal:	Approval of Details Reserved by Conditions 2 (cycle parking) and 4 (noise insulation scheme)of Application number NOTICE/0022/23
Case Officer:	Louise Prew

Click for further information

Comments Details

Comments:	I refer to the Noise Impact Assessment dated March 2024 prepared by Tracesurveys and make the following comments. There is no information provided on the authors or their qualifications. Section 4.2 Survey results - no details are provided on how the daytime and nightime LAeq's were derived. The report references the table but the derived LAeq's do not appear to relate to those provided in that table. There is no description of the types of noise responsible for the LAeq's, this is important as different noise sources will result in different human responses. There is no plan showing where the measurements were undertaken and the relationship to surrounding noise sources. There is no mention of the west elevation facing Tesco Express and any noise impact from operations here.

Kind regards