From: Hannah Powell <hannah.powell@adur-worthing.gov.uk> on behalf of Hannah Powell
Sent: 08 July 2022 09:49
To: Peter Barnett
Subject: Re: 3018 FW: Consultee Comments for Planning Application AWDM/0930/22

Flag Status: Flagged

Peter
Thank you for forwarding this amended Noise Impact Assessment (ref. 5343_002R_2-0_PA dated 7 July 2022). This is acceptable.

Please could the document ref/date referred to in my previous recommended conditions be amended to the above to ensure the most recent Noise Impact Assessment is being referenced?


Also, with reference to Section 8 of the Noise Impact Assessment, due to the predominantly residential nature of the area, we would recommend that a 'noise change' method should be followed when setting threshold noise levels for construction activities.

Many thanks
Hannah Powell

On Thu, 7 Jul 2022 at 16:06, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Hi Hannah
>
> Clarification on distances as requested plus updated noise report. Could I please have your comments?
>
> Thanks

Peter Barnett
Principal Planning Officer, Adur & Worthing Councils
Phone: 01903 221310
Email: peter.barnett@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Address: Planning & Development, Portland House, 44 Richmond Road, Worthing, BN11 1HS



---------- Forwarded message ---------
From: **Melissa Hitchcock** <melissa@burns-guthrie.co.uk>
Date: Thu, 7 Jul 2022 at 15:59
Subject: 3018 FW: Consultee Comments for Planning Application AWDM/0930/22
To: Peter Barnett <peter.barnett@adur-worthing.gov.uk>
Cc: Peter Akhurst <peter@andersonacoustics.co.uk>, Lee Murley (head@seaside.w-sussex.sch.uk) <head@seaside.w-sussex.sch.uk>, Libby Christie <secretary@nhat.co.uk>

Dear Peter

Please see comment below from our Acoustic Consultant and the amended report incorporating 18m distance.

Kind Regards

Mel

burnsguthrie
chartered architects

Tel: 01892 824193

Home working: 01424 773665

Visit our Website

Follow us on Twitter

Take a peek at our Instagram

From: Peter Akhurst <peter@andersonacoustics.co.uk>
Sent: 07 July 2022 15:53
To: Melissa Hitchcock <melissa@burns-guthrie.co.uk>
Cc: Libby Christie <secretary@nhat.co.uk>; Lee Murley (head@seaside.w-sussex.sch.uk) <head@seaside.w-sussex.sch.uk>
Subject: RE: Consultee Comments for Planning Application AWDM/0930/22

Hi Mel,

The calculation in Appendix D used 20m rather than the 18m stated within the text in Section 2. The difference is distance between the two gives rise to a 1dB increase in noise emission prediction. I this is based upon approximately 20m to the rear façade of the house, 18m to the façade of the conservatory.

I attach an updated report with 18m calculations included in appendix D, representing a worst case.

Kind regards,

Peter

--

Hannah Powell
Environmental Health Technician, Public Health & Regulation
01273 263357
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
http://www.adur-worthing.gov.uk/

