From: Michael Lavender <michael.lavender@adur-worthing.gov.uk> on behalf of Michael Lavender
Sent: 09 December 2020 13:53
To: Peter Barnett
Subject: AWDM/1912/20: Caxton House

Flag Status: Flagged

Hello Peter,

The acoustic report sets out that standard double glazing is adequate for noise control, however, windows will need to remain closed to ensure noise standards are met. The applicant is proposing an exhaust ventilation system with additional extract fans in the bedrooms that are prone to overheating. These will depressurise the room drawing air in through the window vents. These window vents will need to be attenuated as advised in the acoustic report. If they can provide details of the proposed acoustic vents for the windows I am happy for this condition to be signed off.

Regards

Michael Lavender