



THE WORTHING SOCIETY

[REDACTED]
Planning Officer
Worthing Borough Council
Town Hall
Chapel Road
Worthing BN11 1HA

16 March 2026
[REDACTED]

[REDACTED]
WORTHING SOCIETY CONSULTATION RESPONSE

AWDM/0298/26 - 6 WARWICK STREET WORTHING WEST SUSSEX BN11 3DL

Replacement aluminium glazing at first floor level on front and east side elevations.

Thank you for requesting our comments in respect of the above planning application regarding replacement aluminium windows.

This building is located in the historic Warwick Street quarter and is within the South Street Conservation Area (CA).

I have now had the opportunity to discuss the proposal with our Heritage Team. Although modern in design, the material is a 'yellow brick' substitute which is not out of character. The building is quite prominent within the CA and occupies a corner site. The existing sash windows would be replaced by bottom openers. These would look incongruous when opened and the frame widths would be different. The replacement windows should, in our view, be the same design as the existing.

In summary and for the reason stated the Society objects to this present application.

Yours sincerely,

[REDACTED]
[REDACTED]

Worthing Society Chair

Cc: [REDACTED] Design & Conservation Architect, Adur & Worthing Councils
Cc: [REDACTED] BSc(Econ), DipTP, MRTPI (Retd) - Worthing Society Heritage Team Lead
Cc: Planning Dept., Adur & Worthing Councils (REDACTED)