



Support Planning <support.planning@adur-worthing.gov.uk>

Consultee Comments for Planning Application AWDM/0651/26

1 message

planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
To: support.planning@adur-worthing.gov.uk

11 September 2026 at 10:48

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11/09/2026 10:48 AM from Mr Oliver Rochford (oliver.rochford@adur-worthing.gov.uk) on behalf of Environmental Protection, Environmental Health & Licensing.

Application Summary

Reference:	AWDM/0651/26
Address:	41 - 43 South Street Worthing West Sussex BN11 3AW
Proposal:	Replacement of three ATMs on the front elevation with new machines; and condenser units to rear roof
Case Officer:	Louise Prew

[Click for further information](#)

Comments Details

Comments:

- Works of construction or demolition, including the use of plant and machinery, necessary for implementation of this consent shall be limited to the following times.

Monday - Friday 08:00 - 18:00 Hours
Saturday 09:00 - 13:00 Hours
Sundays and Bank Holidays no work permitted

Any temporary exception to these working hours shall be agreed in writing by the Local Planning Authority at least five days in advance of works commencing. The contractor shall notify the local residents in writing at least three days before any such works.

Reason: To safeguard the residential amenity of the area.

A Environmental Noise Survey and Plant Noise Assessment Report (ref:33195/PNA1/Rev1, dated:25/06/2026) was submitted in support of this application. The report indicates there will be no adverse impact on the surrounding residential properties as a result of the intended units. Following completion of the installation, a test shall be undertaken to demonstrate that the proposed levels in the scheme are accurate and protect the residential unit from noise.

Kind regards