from Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Your ref
AWDM/0850/20

Our ref
PLAN-033572

Date
01/07/2020

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Conversion of Existing Garage Into Self-Contained Annexe, Including Single-Storey Side Extension and Verandah to East, Including Raising of Roof Height to 2.92m.
Site: AWDM/0850/20: - 40 Connaught Avenue, Shoreham-By-Sea, West Sussex, BN43 5WJ.

Thank you for your letter dated 11/06/2020.

Southern Water requires a formal application for any new connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please read our New Connections Services Charging Arrangements documents which is available to read on our website via the following link:
southernwater.co.uk/developing-building/connection-charging-arrangements

The disposal of surface water from this development shall follow the hierarchy within Part H3 of Building Regulations:

a) An adequate soakaway or some other adequate infiltration system.

b) A water course.

c) Where neither of the above is practicable: a sewer.

The proposed development would lie within a Source Protection Zone around one of Southern Water's public water supply sources as defined under the Environment Agency's Groundwater Protection Policy. Southern Water will rely on your consultations with the Environment Agency to ensure the protection of the public water supply source.

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: developerservices@southernwater.co.uk

Yours faithfully,



Joff Edevane
Growth Planning Lead
Business Channels

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670