From: Marie O'Keeffe
Sent: 30 July 2019 08:02
To: Marie O'Keeffe
Subject: Fwd: AWDM/1038/19 - Piston Broke 88 High Street Shoreham-By-Sea West Sussex BN43 5DB

---------- Forwarded message ---------
From: **Hannah Powell** <hannah.powell@adur-worthing.gov.uk>
Date: Mon, 29 Jul 2019 at 10:01
Subject: AWDM/1038/19 - Piston Broke 88 High Street Shoreham-By-Sea West Sussex BN43 5DB
To: Marie O'Keeffe <marie.o'keeffe@adur-worthing.gov.uk>

Dear Marie
With reference to the above application I have the following comments.


I have concerns of the potential noise escape from the proposed bi-fold windows, the current window of Piston Broke does not appear to be openable and I understand both adjacent premises at 1st floor level are in residential use. Noise from live/recorded music could significantly impact amenity.

I would recommend a condition requiring the windows to be closed after 21:00hrs and at all times during live music. Before 21:00hrs the contribution of music from this premises as measured or predicted should not exceed 55dB LAeq (5mins) 4m from the front of the premises facade.

Regards
Hannah

--

Hannah Powell
Environmental Health Technician, Adur & Worthing Councils
Phone: 01273 263357
Email: hannah.powell@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk/
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



--

Marie O'Keeffe
Senior Planning Officer - Part Time, Adur & Worthing Councils
Phone: 01903 221425
Email: marie.o'keeffe@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

