From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk> on behalf of FRS Water and Access
Sent: 20 March 2023 15:49
To: planning@adur-worthing.gov.uk
Subject: Planning consultation - AWDM/0118/23 Car Park South Street Lancing West Sussex

FAO: Gary Peck

Dear Gary,

Having viewed the plans for the planning application no. AWDM/0118/23 for the redevelopment of existing car park to provide 7no. dwellings for emergency and temporary accommodation with associated works, evidence is required to show suitable turning facility is provided to enable a fire appliance to turn and make their exit. A requirement identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1 and diagram 13.1.

Regards

Ian



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.