Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

ADUR & WORTHING
17 OCT 2013
PLANNING SERVICES

Developer Services
Southern Water
Southern House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: **developerservices@southernwater.co.uk**

Your Ref
AWDM/1242/12
Our Ref
PLAN-004339
Date
15/10/2013

Dear Sir

Proposal: Discharge of Conditions 11 and 12 (Drainage Details) of permission reference AWDM/1242/12.
Site: Land North Of The Globe Primary School, Irene Avenue, Lancing, West Sussex, BN159RR.
AWDM/1242/12

Thank you for your letter of 07/10/2013.

The proposed drainage layout would be satisfactory to Southern Water Services. However, as indicated in our previous correspondence there is insufficient capacity within the existing foul sewerage system to accommodate the proposed development foul flows, therefore Southern Water cannot recommend discharge of condition relating to drainage.

Yours faithfully

[redacted]

Developer Services