From: planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk>
Sent: 11 July 2024 15:41:37 UTC+01:00
To: "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
Subject: Consultee Comments for Planning Application AWDM/0793/24

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 11/07/2024 3:41 PM from Mr Michael Lavender (michael.lavender@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0793/24
Address:	20 Rugby Road Worthing West Sussex BN11 4PZ
Proposal:	Installation of an Air-Source Heat Pump to East elevation
Case Officer:	Jason Albon

Click for further information

Comments Details

Comments:	I note that noise from the air source heat pump complies with the MCS020 Noise Assessment submitted by the applicant and therefore there are no EH objections to this application being permitted.

Kind regards