from Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Your ref
AWDM/0343/22

Our ref
DSA000017295

Date
05/11/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Condition 12 reference to AWDM/0343/22.
Site: AWDM/0343/22: - 5 Commerce Way, Lancing Business Park, Sompting, West Sussex, BN15 8TA.

Further to our response dated 17/10/2022 and additional information provided by the developer regarding permeable paving, Southern Water have no objections to discharge condition 12 relating to protection of public sewers.

Please note: The design of drainage should ensure that no groundwater or land drainage is to enter public sewers.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670