from Southern Water

Planning Services
Adur & Worthing Councils
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/1629/23

Our ref
DSA000029586

Date
20 December 2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Replacement windows and entrance doors, alteration of rear window and door openings, demolition of rear lean-to extensions, removal of chimney stack and replacement of mansard roof, replacement of 2no. dormers, creation of 1no. new dormer, new boundary wall. Resubmission of consented application AWDM/1324/23 with amendments to rear dormers.
Site: AWDM/1629/23: - 8 - 10 Gratwicke Road, Worthing, West Sussex, BN11 4BH.

Thank you for your letter dated 30 November 2023.

Southern Water requires a formal application for any new connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

In situations where surface water is being considered for discharge to our network, we require the below hierarchy for surface water to be followed which is reflected in part H3 of the Building Regulations. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.

- Reuse

- Infiltration

- Watercourse

- Storm Sewer

- Combined Sewer

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

Guidance on Building Regulations is here:
gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670