Gmail

Planning - <planning@adur-worthing.gov.uk>

Planning application AWDM/1549/24

1 message

[redacted] 11 December 2024 at 12:05

To: planning@adur-worthing.gov.uk

Hi.

Thank you for the notification regarding the subject planning application.

Our garden backs onto that of 37 Windsor Road.

We have experience of various heat pump installations both here in the UK and Switzerland.

We are well aware that heat pumps generate noise that can vary in intensity from almost silent to intrusive.

I have read the subject planning application but am unable to find any mention for the environmental impact for this installation.

We are, therefore, opposing this application on the ground that it does not contain any provisions for the control of noise pollution to ensure any such pollution does not exceed 40db and the actions to be taken should this threshold be exceeded.

Yours sincerely

R J and S A Hobbs
14 Gannon Road
BN11 2DT

[redacted]