From: planning@adur-worthing.gov.uk
Sent: 04 November 2021 08:25
To: planning@adur-worthing.gov.uk
Subject: Consultee Comments for Planning Application AWDM/1915/21

Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 04/11/2021 8:24 AM from Ms Laura Gibbons (laura.gibbons@adur-worthing.gov.uk) on behalf of Technical Services.

Application Summary

Reference:	AWDM/1915/21
Address:	59 Halewick Lane Sompting Lancing West Sussex BN15 0ND
Proposal:	Approval of Details Reserved by Conditions: Condition 3 (Materials); Condition 4 (Surface Water Drainage Details) and Condition 6 (Construction Management Plan Details) of approved application AWDM/2030/20
Case Officer:	Marie O'Keeffe

Click for further information

Comments Details

Comments:	Dear Marie, Thank you for consulting us, we have the following comments regarding condition 4: - Winter groundwater monitoring and winter infiltration testing have been completed. The tests results show an infiltration rate which is acceptable for soakaway design. - Calculations and a design based upon the infiltration testing results needs to be supplied. Further guidance on this can be found within our surface water drainage guidance notes and checklist which are located here: https://www.adur-worthing.gov.uk/planning/applications/submit-fees-forms. Kind regards, Laura Gibbons

Kind regards