Amanda Haslett
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

2 February 2026

Dear Amanda,

RE: **AWDM/1209/25 - Greater Brighton Metropolitan College Littlehampton Road Worthing West Sussex.**

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the approval of details reserved by conditions 5 (surface water drainage), 8 (archaeological mitigation), 9 (CO2 reduction and renewable energy) and 14 (BNG) of AWDM/0447/24. The application is to Worthing Borough Council.

Following a review of the updated information since our response dated 6th January 2026, we note that updated calculations have been received that match the area of permeable paving in the as built drawings. We note the calculations show minor flooding in the 1 in 100 year plus climate change scenario but this is safely contained on site. **Therefore, sufficient information has been received for the discharge of Condition 5.**

Yours sincerely,

Sustainable Water Management Officer

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com

WSP UK Limited | Registered address: WSP House, 70 Chancery Lane, London WC2A 1AF
Registered in England and Wales No. 01383511