from Southern Water

Adur & Worthing Council
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/1619/24

Our ref
DSA000039975

Date
10/01/2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Change of use from cafe and escape room to restaurant (Use Class E) with external extract ducting.
Site: 24 - 26 Portland Road Worthing West Sussex BN11 1QN.

Thank you for your correspondence dated the 6th of January 2025, please see our comments below regarding the above application.

Connection to public sewer

Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer. To make an application visit Southern Water's Get Connected service: https://developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: https://www.southernwater.co.uk/developing-building/connection-charging-arrangements

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

Disposal of surface water

In situations where surface water is being considered for discharge to our network, we require the below hierarchy for surface water to be followed which is reflected in part H3 of the Building Regulations. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

- Reuse
- Infiltration
- Watercourse
- Storm Sewer
- Combined Sewer

Guidance on Building Regulations is here: https://www.gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h

We would like to engage with you on the design for disposal of surface water for this development at the earliest opportunity and we recommend that civil engineers and landscape architects work together and with Southern Water. In many cases this may negate or reduce the need for network reinforcement and allow earlier completion of the development.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk
Yours faithfully,
Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670