From: Kyran Schneider <Kyran.Schneider@westsussex.gov.uk> on behalf of Kyran Schneider
Sent: 09 June 2023 14:10
To: Peter Barnett
Subject: RE: 44 Brighton Rd, Lancing - AWDM/0077/23

Flag Status: Flagged

Hi Peter,

I have taken a look at the submitted Site Set-Up Plan, and the details provided are acceptable from our point of view.

Kind regards
Kyran

Kyran Schneider BSc (Hons) MCIHT | Planning Technician | Information Management | Planning Services
West Sussex County Council
Location: Ground Floor, Northleigh, Chichester, PO19 1RH

Internal: 29362 | External: 0330 22 29362| E-mail: Kyran.Schneider@westsussex.gov.uk

---

From: Peter Barnett <peter.barnett@adur-worthing.gov.uk>
Sent: 08 June 2023 08:59
To: Kyran Schneider <Kyran.Schneider@westsussex.gov.uk>; SU Local Development <SULocalDevelopment@westsussex.gov.uk>
Subject: Fwd: 44 Brighton Rd, Lancing - AWDM/0077/23

****EXTERNAL****

Hi Kyran

Could I please have your response to my email below?

Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk



---------- Forwarded message ---------
From: **Peter Barnett** <peter.barnett@adur-worthing.gov.uk>
Date: Tue, 16 May 2023 at 16:02
Subject: Fwd: 44 Brighton Rd, Lancing - AWDM/0077/23
To: Kyran Schneider <kyran.schneider@westsussex.gov.uk>, <sulocaldevelopment@westsussex.gov.uk>

Hi Kyran

I have now received a revised CMP and plan, attached. Please could you confirm if this is now satisfactory so that I may discharge the condition?

Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk



---------- Forwarded message ---------
From: **Linda Turner** <linda@inature.co.uk>
Date: Mon, 15 May 2023 at 14:00
Subject: Re: 44 Brighton Rd, Lancing - AWDM/0077/23
To: Peter Barnett <peter.barnett@adur-worthing.gov.uk>

Hi
Please find attached the CMP from the appointed contractor.

Regards
Linda

Linda Turner RIBA

T. 01273 710056
M. 07966 039832

Featured in House and Home, Financial Times Nov 26 2022
Most Innovative Sustainable Architecture & Interior Design Studio 2022

Southern Enterprise Awards 2022

www.inature.co.uk

Confidentiality Notice:
This email (and any attachment) is intended only for the addressee. Its unauthorised use, disclosure, storage or copying is not permitted. If you are not the intended recipient, please destroy all copies and inform the sender by return email.

On Tue, 28 Feb 2023 at 11:59, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Dear Linda
>
> Are you able to send me the revised CMP yet?
>
> Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk

On Thu, 9 Feb 2023 at 19:30, Linda Turner <linda@inature.co.uk> wrote:

> Hi
> Please find attached the amended drainage strategy report, taking into account the comments received.
> The contractors' statement will follow on.
>
> Regards
> Linda

Linda Turner RIBA

T. 01273 710056
M. 07966 039832

Featured in House and Home, Financial Times Nov 26 2022

Most Innovative Sustainable Architecture & Interior Design Studio 2022

Southern Enterprise Awards 2022

www.inature.co.uk

Confidentiality Notice:
This email (and any attachment) is intended only for the addressee. Its unauthorised use, disclosure, storage or copying is not permitted. If you are not the intended recipient, please destroy all copies and inform the sender by return email.

On Fri, 3 Feb 2023 at 03:53, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Dear Linda
>
> With reference to the application for approval of details, I have received the following comments:
>
> **Condition 3 (drainage)**:
>
> Our Engineer has stated:
>
> The Surface water Drainage strategy provided by Meridian has provided details and calculations based upon the infiltration rates provided for an adjacent location approx. 87m away from the proposed development. This is okay in principle. We would, however,recommend testing is carried out at the location of the proposed structure prior to providing full drainage details.
>
> Meridian's Strategy also indicates a soakaway zone of 3.5m x 3.5m whilst the calculations and drainage layout proposes a soakaway of 4.5m x 5m . The soakaway zone appears to be very close to the proposed boundary line. This is not acceptable for the following reasons. Drainage should be contained within the boundary of the dwelling and should be kept 2.5m away from property boundaries, this is to try to limit any potential issues with development on adjoining sites (which we won't have control over) if soakaways are located right up to or over boundaries it is likely that they will cause damage (heave for example) to potential future buildings. Soakaways should also not be positioned under fence lines or trees/ hedges as roots and foundations will likely damage the soakaway.
>
> **Condition 9 (CMP):**
>
> WSCC Highways have said:
>
> The applicant has submitted a Construction Management Plan (CMP) document. However, no specific details relating to the above-mentioned requirements for Condition 9 have been provided. Can the LPA request the following details from the applicant, and also have them demonstrate the location of said details on a site plan: • The parking of vehicles of site operatives and visitors, • Area for loading/unloading of plant and materials. • Area for storage of plant and materials. • Details of security hoarding. • Location of wheel-washing facilities.
>
> Would you please submit the required details/amendments for both conditions.
>
> Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.