Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 16/04/2025 10:37 AM from Mr Nadeem Shad (nadeem.shad@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0503/25
Address:	5A Broadwater Street East Worthing West Sussex BN14 9AA
Proposal:	Approval of Details Reserved by Conditions 5 (external noise) and 8 (foul/surface water details) of application AWDM/1399/24.
Case Officer:	Jackie Fox

Click for further information

Comments Details

Comments:	The Noise Impact Assessment of March 2025 concludes that mechanical ventilation to the standards contained within Approved Document F is required for the Broadwater Road facade. The applicant should therefore be requested to submit details of the final ventilation scheme to confirm it has been installed.