BLOCK COMPLIANCE
Calculation Type: New Build (As Built)

Design SAP
elmhurst energy

Block Reference	3	**Issued on Date**	06/08/2020
Block Name	Block 3		
Assessor Details	Mr. Malcolm Maclean, SRE Limited, Tel: 01730 710044, malcolm@sre.co.uk	**Assessor ID**	V497-0002
Client			

Block Compliance Report - DER

Block Reference: 3		Block Name: Block 3		
Property-Assessment Reference	**Multiplier**	**Floor Area (m^2)**	**DER ($kgCO_2/m^2$)**	**TER ($kgCO_2/m^2$)**
PMCC-ROPE-1655-120-ABF	1	71	20.24	21.13
PMCC-ROPE-1655-119-ABF	1	80	25.08	24.12
PMCC-ROPE-1655-118-ABF	1	70	27.68	25.63
PMCC-ROPE-1655-117-ABF	1	50	29.66	28.07
PMCC-ROPE-1655-116-ABF	1	71	15.09	18.15
PMCC-ROPE-1655-115-ABF	1	80	19.98	20.90
PMCC-ROPE-1655-114-ABF	1	70	22.34	22.34
PMCC-ROPE-1655-113-ABF	1	50	24.09	24.63
PMCC-ROPE-1655-112-ABF	1	71	21.12	23.40
PMCC-ROPE-1655-111-ABF	1	80	25.71	26.38
PMCC-ROPE-1655-110-ABF	1	70	28.13	27.79
PMCC-ROPE-1655-109-ABF	1	50	31.03	30.64
Totals:	12	813	290.15	293.18
Average DER = 23.84 $kgCO_2/m^2$			PASS	
Average TER = 24.15 $kgCO_2/m^2$				

Block Compliance Report - DFEE

Block Reference: 3		Block Name: Block 3		
Property-Assessment Reference	**Multiplier**	**Floor Area (m^2)**	**DFEE ($kWh/m^2/yr$)**	**TFEE ($kWh/m^2/yr$)**
PMCC-ROPE-1655-120-ABF	1	71	26.61	30.89
PMCC-ROPE-1655-119-ABF	1	80	38.76	44.95
PMCC-ROPE-1655-118-ABF	1	70	41.01	46.47
PMCC-ROPE-1655-117-ABF	1	50	41.30	45.58
PMCC-ROPE-1655-116-ABF	1	71	13.97	19.33
PMCC-ROPE-1655-115-ABF	1	80	29.24	34.38
PMCC-ROPE-1655-114-ABF	1	70	31.39	35.59
PMCC-ROPE-1655-113-ABF	1	50	30.35	34.01
PMCC-ROPE-1655-112-ABF	1	71	28.26	38.61
PMCC-ROPE-1655-111-ABF	1	80	39.93	52.37
PMCC-ROPE-1655-110-ABF	1	70	41.92	53.66
PMCC-ROPE-1655-109-ABF	1	50	44.32	54.17
Totals:	12	813	407.07	490.01
Average DFEE = 33.61 $kWh/m^2/yr$			PASS	
Average TFEE = 40.63 $kWh/m^2/yr$				