**From:** FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
**Sent:** 07 January 2025 13:40:48 UTC+00:00
**To:** "planning@adur-worthing.gov.uk" <planning@adur-worthing.gov.uk>
**Subject:** Discharge of planning condition - AWDM/1572/24 and At Former Gas Works Site Park Road Worthing West Sussex

FAO: Louise Prew

Dear Louise,

Having reviewed the details for planning application No. AWDM/1572/24 for the approval of the fire hydrant condition raised, providing the new fire hydrant indicated on the plan submitted is in place, ready for use and West Sussex Fire & Rescue Service (WSFRS) are informed it is ready for use the condition raised will be met. Unfortunately, on far too many occasions WSFRS are not informed fire hydrants are in place and ready for use prior to any occupation of the new blocks of flats, which then increases the risk to lives and homes in the event of a fire occurring.

Regards

Ian

**Ian Stocks**
Water & Access Manager - Protection
**West Sussex Fire & Rescue Service**
**Office** 0330 222 4499 **Mobile** 07921 291051
**Web** www.westsussex.gov.uk/fire
**Email** frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

**My pronouns are he/him/his**
Click here to find out why we use pronouns in our signatures




LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.