

From: **Michael Lavender**

Date: Thu, 16 Apr 2026 at 13:44

Subject: AWD/0103/26: 39 Brighton Road, Worthing.

To: Louise Prew <[louise.prew@adur-worthing.gov.uk](mailto:louise.prew@adur-worthing.gov.uk)>

Hi Louise,

there are no EH objections in principle. The sound insulation scheme outlined in the Acoustic South East Report between the commercial and residential is satisfactory. Obviously this still needs to be installed and tested. should be conditioned. So I would include a condition for this purpose see below.

An overheating assessment is still needed, but either of the two ventilation schemes referred to in the Acoustic South East report are acceptable so long as they are sufficient to manage overheating. We just need to know which option they choose. I would include a condition for this purpose, see below.

- The sound insulation of the floor/ceiling between the ground floor commercial unit and first floor residential shall achieve a minimum airborne sound insulation value of 50dB (DnTw + Ctr dB). Before the residential unit is occupied a test shall be undertaken to demonstrate compliance with this level
- Construction work shall not commence until a scheme for protecting the proposed noise sensitive development from external noise has been submitted to and approved by the local planning authority All works, which form part of the scheme, shall be completed before any part of the noise sensitive development is occupied. The scheme shall have regard to the principles contained within the ProPG: Planning & Noise – New Residential Development, 2017 and achieve the indoor ambient noise levels for dwellings specified in BS8233:2014. The scheme should be of good acoustic design, include full details of glazing, ventilation and a strategy to prevent overheating. The noise level of any ventilation units when in use should not exceed the levels specified in BS8233:2014 and all duct work should be fitted on anti-vibration mounts. Following approval and completion of the scheme, a test shall be undertaken to demonstrate that the attenuation measures proposed in the scheme are effective and protect the residential unit from noise.

Regards

**Michael Lavender**

Senior Environmental Health Officer

Environmental Health  
Adur & Worthing Councils

Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA