



Rebekah Hincke
Adur & Worthing Councils
Portland House,
Richmond Road,
Worthing,
BN11 1LF

22 June 2026

Dear Rebekah,

**RE: AWD/0483/26 – Land At Corner Of Union Place And South Of 65 High Street
Worthing West Sussex.**

Thank you for your consultation on the above site. We have reviewed the application as the drainage consultant acting on behalf of the Council and wish to make the following comments.

The applicant is applying for the construction of a single storey kiosk building for commercial use (Use Class E) with new wall to western elevation. The application is to Worthing Borough Council.

Following a review of the submitted information, we have no objection on surface water grounds. Due to the site, size, location, and type of development **we would recommend the approval of the application** with the following informative:

Informative 1: The applicant should consider the use of SuDS (such as rain gardens or water butts), where possible, within their drainage strategy to provide runoff betterment. If utilising infiltration, the applicant should conduct an infiltration test in accordance with the Part H2, paragraph 1.34 to 1.37 of the Building Regulations (https://assets.publishing.service.gov.uk/media/5a80cf9ded915d74e33fc8ae/BR_PDF_AD_H_2015.pdf). This rate should then be put into the calculation in Part H3, paragraph 3.28. Following this the applicant can use the free tools at <https://www.uksuds.com/> to size the soakaway for the 1 in 100 (1%) plus CC event. To obtain the relevant rainfall data the applicant can visit <https://fehweb.ceh.ac.uk/> to download the point data for their site and input the csv file into the tools above.

Yours sincerely,

Sustainable Water Management Officer

Matrix House
Basing View
Basingstoke, Hampshire
RG21 4FF
Tel: +44 1256 318 800
wsp.com