Consultee Comments for Planning Application AWDM/0790/21

1 message

planning@adur-worthing.gov.uk <planning@adur-worthing.gov.uk> 22 June 2021 at 14:43
To: planning@adur-worthing.gov.uk

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 22/06/2021 2:43 PM from Mrs Hannah Powell (hannah.powell@adur-worthing.gov.uk) on behalf of Environmental Health Public Health.

Application Summary

Reference:	AWDM/0790/21
Address:	The Shoreham Centre Pond Road Shoreham-By-Sea West Sussex BN43 5WU
Proposal:	Installation of 8no. air source heat pumps on roof
Case Officer:	Peter Barnett

Click for further information

Comments Details

Comments:	With reference to the above application, given the location and distance of the proposed air source heat pumps from the nearest residential dwelling I do not believe that noise generated by these units will negatively affect amenity. I understand these air source heat pumps will only operate during daytime hours, I would recommend a condition restricting the hours of use to between 07:00hrs - 23:00hrs on any day.

Kind regards