



Stability: Stable

			Trial Pit Log			Trialpit No SA2 Sheet 1 of 1			
Project Name: Sompting			Project No. 20612		Co-ords: 516573.20 - 105451.24 Level: 18.85		Date 27/05/2014		
Location: West Sussex			Dimensions (m):			1.90		Scale 1:20	
Client: Persimmon Homes South Coast			Depth 2.00					Logged PSS	
Samples and In Situ Testing			Depth (m)	Level (m)	Legend	Stratum Description			
Depth	Type	Results							
			0.20	18.65		Brown slightly gravelly SILT. Gravel of subangular to subrounded, fine to medium flint. (MADE GROUND)			
						Light brown slightly clayey gravelly SILT. Gravel of angular to subrounded fine to coarse flint.(HEAD DEPOSITS)			
			0.90	17.95		Yellow gravelly SAND. Sand is coarse. Gravel is fine to cobble subangular to rounded flint. (HEAD DEPOSITS)			
			2.00	16.85	End of pit at 2.00 m				
Remarks:			Site cleared with Cable Avoidance Tool and Excavated with a JCB 3CX. No groundwater encountered.						
Stability:			Stable						

			Trial Pit Log			Trialpit No SA3 Sheet 1 of 1		
Project Name: Sompting			Project No. 20612		Co-ords: 516469.57 - 105347.69 Level: 16.68		Date 27/05/2014	
Location: West Sussex			Dimensions (m): Depth 2.00 0.60 1.80			Scale 1:20 Logged PSS		
Client: Persimmon Homes South Coast								
Samples and In Situ Testing			Depth (m)	Level (m)	Legend	Stratum Description		
Depth	Type	Results						
			0.30	16.38		Brown slightly gravelly SILT. Gravel of subangular to subrounded, fine to medium flint. (MADE GROUND)		
			1.20	15.48		Light brown slightly clayey gravelly SILT. Gravel of angular to subrounded fine to coarse flint. (HEAD DEPOSITS)		
			2.00	14.68		Yellow slightly gravelly SAND. Sand is coarse. Gravel is, angular to rounded fine to cobble size flint (HEAD DEPOSITS).		
						End of pit at 2.00 m		
Remarks: Site cleared with Cable Avoidance Tool and Excavated with a JCB 3CX. No groundwater encountered.								
Stability: Stable								